

04 SEPTEMBER 2017

QUOTATIONS ARE HEREBY REQUESTED IN ACCORDANCE WITH THE SCM REGULATIONS SECTION 18 OF THE LOCAL GOVERNMENT MUNICIPAL FINANCE ACT 56 OF 2003, FOR THE PURCHASE OF ITEM/S THAT COULD BE ABOVE R30 000.00.

QUOTATIONS MUST BE SUBMITTED IN SEALED ENVELOPES CLEARLY MARKED **“IMPUMELELO EXT 02 SEWER PUMP STATION ELECTRIC PANEL REPAIRS”** TO THE QUOTATION BOX SITUATED AT: RATES AND TAXES HALL (LESEDI OFFICES)

C/O LOUW AND HF VERWOERD STREET
HEIDELBERG
1441

ALL ENQUIRIES SHOULD BE REFERRED TO MR. OBED KGOLANE (016) 492 0070 OR MS. SIBULELO NXATHI @016 492 0202.

DEPARTMENT: INFRASTRUCTURE SERVICES

CLOSING DATE: 12 SEPTEMBER 2017@12H00

SPECIFICATIONS: IMPUMELELO EXT 02 SEWER PUMP STATION ELECTRIC PANEL REPAIRS

SERVICES TO BE DELIVERED

- Supply, wire and install a new Electrical Panel for the control of 2x22KW submissible pumps in Devon Ext2.
- The pumps to be controlled manually and automatically.
- The pumps to be fully protected (Electrically and Surge arrestor).
- An Anti-thief system (alarm) to be installed.
- Pumps to be controlled alternatively.

Material list

Description	Quantity	Price	VAT Price	Nat Price
950x 700x 270 sheet metal enclosure	01			
63A, 40KA pole adjustable MCCB	02			
125A, 3pole load break switch with shaft	01			
22KW, 380V-460V,3 PH AC motor VSD	02			
240V, 11 pin, 10A delay on relay	01			
240V, 11 pin, 10A thermistor relay	02			
240V, 11 pin, 10A industrial relay	06			
240V,11 pin,10A Multirange Tiner relay	02			
240V, 2 steps (Flip Flop relay)	01			
240V, 12A, 3 pole magnet Contactor	02			
240V, 9A, 3 pole magnet Contactor	02			
400V, 9A to 24V,150VA Transformer	01			
24VAC, 11 pin, 10A industrial relay	04			
63A, 4 pole terminal block	02			

**All
Consumable**

6mm DIN terminal with accessories	14			
6A, 1 pole MCB	01			
10A, 3 pole fuse holder with fuses	01			
CL, 2 surge protection 30KA 3 PH	01			
72x 72, 600V AC volt meter	01			
3 position 22mm selector switch plus contact	01			
Push button plus contacts	04			
E/stop push button twist release	01			
22mm, 240v pilot lights	07			
One Set alarm system	01			
Length earth spike and accessories	02			
10 x 4 flex cable	6m			
Roll panel wire (grey, black)	02			
15m, 35mm earth cable	02			
Length 60x 80 slotted trucking	03			

- Cable ties
- Lugs
- Labels
- Row bolts

Labour Cost

- Wiring and Installation
- Commissioning
- All Travelling's

You are required to submit an official quote on the company letterhead.

Name of Company: _____

Fax: _____

Telephone: _____

Date: _____

The following documents must be submitted with the quotation, failure in submitting these documents will result in a quotation being disqualified:

- Original tax clearance certificate/SARS Tax pin
- Forms listed below (MBD 2, MBD 4, MBD 6.1, MBD 8 and MBD 9)
- Latest municipal account
- CSD Registration report

Bidders who did not submit an original or certified copy of their BBBEE Certificate will not be allocated preference points and will only be evaluated on price.

Evaluation Criteria: 80/20 Preference point system as presented in the Preferential Procurement Policy Framework Act no 5 of 2000, for this purpose MBD 2, MBD 4, MBD 6.1 MBD 8, MBD 9 and the Clearance certificate for water & lights can be downloaded on our website on the following link: www.lesedilm.gov.za/key/scm. MBD forms should be scrutinized, completed and submitted together with your quotation. All objections and complaints must be lodge within 14 days and in writing to the municipal's manager's office.

All bidders must ensure that they are registered on the National Treasury Central Supplier Database via the following link: business.support@csd.gov.za. No business will be conducted with any person who is not registered on this

